



KEY PLAN, 102ND FLR ONE W.T.C.
NOT TO SCALE

GENERAL NOTES

- ALL WORK SHALL BE PERFORMED IN ACCORDANCE WITH THE REQUIREMENTS OF THE NEW YORK CITY BUILDING CODE, THE NATIONAL ELECTRICAL CODE, AND THE PORT AUTHORITY OF NEW YORK AND NEW JERSEY STANDARDS.
- ALL CABLE SPECIFICATIONS SHALL BE APPROVED BY THE PORT AUTHORITY PRIOR TO THE PURCHASE AND INSTALLATION.
- ALL EQUIPMENT SHALL BE GROUNDED TO BARE BUILDING STEEL WITH #8 GROUND WIRE.
- NEW YORK TELEPHONE COMPANY WILL PROVIDE RJ21X INTERFACE COUPLER IN ACCORDANCE WITH THEIR SPECIFICATIONS.
- ALL CABLE SHALL BE TAGGED AS TO TENANT AND SYSTEM IDENTITY.
- ALL ELECTRICAL WORK IS BEING SUBMITTED UNDER A SEPARATE PORT AUTHORITY APPLICATION.
- MAIN DISTRIBUTION-FRAME (MDF) TO BE 3/4" PLYWOOD, FIRE RETARDANT, TREATED PER NYC BUILDING CODE SECTION C-26-502.6.
- WIRING FOR 30 NEW TELEPHONE INSTRUMENTS IS BEING INSTALLED UNDER THIS APPLICATION.
- SEE SPECIFICATIONS SHEET FOR EQUIPMENT SPEC'S FOR EQUIPMENT BEING INSTALLED OTHER THAN TELEPHONE SHOWN ON PLAN.
- GENERAL OFFICE, TRADING ROOM, COMPUTER ROOM, AND MAIL ROOM ARE ON RAISED FLOOR.

EQUIPMENT DESCRIPTION AND QUANTITIES

CABLE TYPE: 3 PAIR PLENUM WITH TEFLON JACKET INSULATION 24GA
 QUANTITY: 30 (ALL ARE WIRED, SOME WILL BE FUTURE)
 MANUFACTURER: PANASONIC
 STATION EQUIPMENT: PANASONIC
 EQUIPMENT: PANASONIC - DVS

SYMBOL LEGEND:

- = FLOOR MOUNTED TELEPHONE OUTLET IN FLOOR DUCT (BY OTHERS)
- = WALL MOUNTED TELEPHONE OUTLET (BY OTHERS)
- = FLOOR MOUNTED TELEPHONE OUTLET IN RAISED FLOOR (BY OTHERS)
- = ELECTRONIC EQUIPMENT (SEE SPEC, SHEET)

TC/ATA NO. 4643-PC-563
 CONTRACT NO. 591-977
 DATE APPROVED 1/24/91

NO.	1-9-91	REVISION	REVISED PER PORT AUTH. COMMENTS & RELOCATE 4 TV CAMERAS
<p>NICHIEI SYSCOM NICHIEI SYSTEM COMMUNICATION & CONSTRUCTION, INC. TELECOMMUNICATION CONSULTANTS & CONTRACTORS</p>			
<p>intradesign group inc 920 BROADWAY / NEW YORK, 10010 / 212/505.0777</p>			
<p>TELEPHONE & COMMUNICATIONS PLAN</p>		<p>Scale 1/8" = 1'-0"</p>	
<p>THE NISHI-NIPPON BANK LTD. ONE WORLD TRADE CENTER NEW YORK, N.Y.</p>		<p>ISSUE DATE NOV 29, 1990 REV. DATE JAN 9, 1991</p>	
<p>Client</p>		<p>T-1</p>	

